

The Meter Setter



Ford Meter Box Product Submittals


For decades The Ford Meter Box Company, Inc. has provided submittals to our customers for fast, easy, and accurate information about our products, allowing for an efficient approval process. It is standard practice for engineers and contractors to refer to submittals when working with a municipality or public works project. Features of the Ford submittal may include drawings, product data, dimensions, pressure ratings, component material, and applicable conforming standards.

Using standardized forms, the Ford submittal is a concise and convenient means to communicate important details of a specific product. With a growing online library of more than 2800 submittals, representing tens of thousands of products, Ford offers 24/7 availability through our website. To download any of our submittal forms, point your browser to www.fordmeterbox.com and select Submittals from the menu bar.

Item Title


SUBMITTAL INFORMATION

Ballcorp Corporation Stops - (FB1000-x-NL style)



Product Profile

AWWA/CC TAPER THREAD INLET BY PACK JOINT FOR COPPER OR PLASTIC TUBING (CTS) OUTLET



Product cut-a-way showing components and dimensions

Part Number Table

VALVE SIZE	INLET SIZE	OUTLET SIZE	VALVE LENGTH	BODY OUTLET THREADS	APPROX. WT. LBS	PART NUMBER	✓ SUBMITTED ITEM(S)
1-1/4"	1-1/4"	1-1/4"	5-15/16"	1-1/4" Flare Copper	4.9	FB1000-5-NL	
1-1/4"	1-1/4"	1-1/2"	5-7/8"	1-1/2" Flare Copper	5.7	FB1000-56-NL	
1-1/2"	1-1/2"	1-1/2"	6-9/16"	1-1/2" Flare Copper	6.9	FB1000-6-NL	
1-1/2"	1-1/2"	2"	6-9/16"	2" Flare Copper	8.5	FB1000-67-NL	
2"	2"	2"	7-7/16"	2" Flare Copper	11.1	FB1000-7-NL	
2"	2"	2-1/2"	7-9/16"	2-1/2" Flare Copper	10.9	FB1000-78-NL	

Note: Ford recommends using insert stiffeners with plastic pipe or tubing.



Identifying Marks and Logos

Features

FEATURES

- All brass that comes in contact with potable water conforms to AWWA standard C800 (UNS NO C89833)
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B-62 and ASTM B-584, UNS NO C83600 - 85-5-5-5)
- The product has the letters "NL" cast into the main body for proper identification
- UL Classified to ANSI/NSF Standard 61 and Annex G
- Ends are integral or secured with adhesive to prevent unintentional disassembly
- 300 PSI working pressure

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.

Ford Corporate Information



The Ford Meter Box Company, Inc.
P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443
Phone: 260-563-3171 / Fax: 800-826-3487
Overseas Fax: 260-563-0167
<http://www.fordmeterbox.com>

Submitted By:

Submitted By



The Ford Meter Box Co., Inc. 775 Manchester Avenue, P.O. Box 443, Wabash, Indiana, USA 46992-0443
Telephone: 260/563-3171 FAX: 1-800-826-3487 Overseas FAX: 260/563-0167 <http://www.fordmeterbox.com>