



The Ford Meter Box Company, Inc.

775 Manchester Avenue • P.O. Box 443, Wabash, Indiana U.S.A. 46992-0433
Phone: 260-563-3171 • Fax: 800-826-3487 • Overseas Fax: 260-563-0167 • www.fordmeterbox.com

April 4, 2023

FORD® 202BSD SERVICE SADDLES

This is to certify that 202BSD saddles, as manufactured by The Ford Meter Box Company, Inc., meet all applicable standards of ASTM (Specification B62 and/or ASTM B584, UNS/CDA No. C83600) and the American Water Works Association, including AWWA Standard C800 and latest revisions. These saddles shall be manufactured from a copper alloy CDA No. C83600, having a metal content consisting of 85% copper and 5% each of tin, lead and zinc (85-5-5-5 spec). The Ford Meter Box Company, Inc. receives certification for and tests each brass ingot shipment upon arrival to ensure that the ingot conforms to this specification. Brass saddles (in most states) are not required to comply with the no-lead requirements stated in the United States Public Law 111-380. 202BSD saddles are certified to NSF/ANSI 61.

The saddle bands, 5/8" UNC threaded bolts, nuts, and washers are type 304 Stainless Steel. The heavy hex nuts will be coated to prevent galling. All welds are fully passivated for corrosion resistance. The gasket is EPDM rubber per ASTM D2000.

Ford® 202BSD saddles, up through 12" nominal pipe size, shall be rated for the lesser of either 150 psi water pressure or the pipe rating, if properly installed and maintained under normal service conditions, as long as the O. D. of the pipe remains constant.

The Ford Meter Box Company holds a certificate of registration to the International Standards Organization for the latest ISO 9001 Standard.

THE FORD METER BOX COMPANY, INC.

Todd Hodson
Marketing Manager