



# The Ford Meter Box Company, Inc.

775 Manchester Avenue • P.O. Box 443, Wabash, Indiana U.S.A. 46992-0433  
Phone: 260-563-3171 • Fax: 800-826-3487 • Overseas Fax: 260-563-0167 • [www.fordmeterbox.com](http://www.fordmeterbox.com)

March 9, 2022

## **FORD® PLASTIC PIT SETTERS**

This is to certify that all brass components for plastic pit setters as manufactured by The Ford Meter Box Company, Inc., with a "-NL" designation at the end of the catalog number shall contain no more than 0.25% lead by weight. The brass alloy used for all surfaces coming in contact with potable water shall meet the requirements of UNS/CDA number C89833 as listed in ANSI/AWWA C800 Standard and the products produced with this alloy shall meet the ANSI/NSF Standard 61 and/or ANSI/NSF Standard 372 as applicable, complying with the Safe Drinking Water Act.

Brass components that do not come in contact with potable water shall meet the requirements of ASTM B62 and ASTM B584, using UNS/CDA number C83600.

The copper tubing conforms to ASTM B88 or B75, UNS C12200 as applicable. The solid wall PVC housing shall be per ASTM D2241 or ASTM D1784. Corrugated PVC tile shall be per ASTM F949. All solder joints shall contain lead-free solder.

The Ford Meter Box Company holds a certificate of registration to the International Standards Organization for the latest ISO 9001 Standard.

THE FORD METER BOX COMPANY, INC.

A handwritten signature in black ink, appearing to read "Todd A. Hodson".

Todd Hodson  
Marketing Manager