



# SUBMITTAL INFORMATION

## Brass Saddles For C900 PVC - (101BS-962-TAP style)



### 101BS SINGLE BAND BRASS SADDLES



| NOM. PIPE SIZE | SADDLE O.D. RANGE | APPROX. WT. LBS. | TAP SIZE & TYPE | CATALOG NUMBER | ✓ SUBMITTED ITEM(S) |
|----------------|-------------------|------------------|-----------------|----------------|---------------------|
| 8"             | 9.05-9.62         | 4.0              | 3/4" AWWA       | 101BS-962-CC3  |                     |
|                |                   |                  | 1" AWWA         | 101BS-962-CC4  |                     |
|                |                   |                  | 3/4" IP         | 101BS-962-IP3  |                     |
|                |                   |                  | 1" IP           | 101BS-962-IP4  |                     |
|                |                   |                  |                 |                |                     |

#### FEATURES

- All brass conforms to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS NO C83600 - 85-5-5-5)
- Bands and 5/8" UNC threaded studs are made of type 304 stainless steel. Welds are fully passivated for corrosion resistance
- Gasket is EPDM rubber ASTM D2000
- Stainless steel nuts are coated to prevent galling

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current. Our standard warranty applies.



**The Ford Meter Box Company, Inc.**  
P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443  
Phone: 260-563-3171 / Fax: 800-826-3487  
Overseas Fax: 260-563-0167  
[www.fordmeterbox.com](http://www.fordmeterbox.com)

Submitted By:

06/06/23