


SUBMITTAL INFORMATION

Angle Ball Meter Valve Assembly - (BA43-342W-U-AWT-NL style)



ULTRA-TITE (CTS) COUPLING ASSEMBLED WATERTIGHT TO BALL VALVE WITH METER SWIVEL NUT



VALVE SIZE	ULTRA-TITE SERVICE LINE O.D.	METER SIZE	LENGTH (IN.)	HEIGHT (IN.)	APPROX. WT. LBS	PART NUMBER	✓ SUBMITTED ITEM(S)
3/4"	1.120 - 1.130	5/8" x 3/4" & 3/4"	2-9/32	4	2.4	BA43-342W-U-AWT-NL	

Note: Ford recommends using insert stiffeners with plastic pipe or tubing.

FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters "NL" cast into the main body for lead-free identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- Ends are integral or secured with adhesive to prevent unintentional disassembly
- Hole for attaching handle is provided in the tee head
- 150 PSI working pressure
- Padlock wing for locking valve in closed position
- Ultra-Tite assembled watertight to ball valve
- Ball valve body design provides larger, more rugged wrench flats for easy installation
- Optional** WW valves can be locked in either the open or closed position

Note: Recommended for inlet side shut-off.
Optional full 360° tee-head rotation. Add "R" to end of part number.

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current. Our standard warranty applies.



The Ford Meter Box Company, Inc.
 P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443
 Phone: 260-563-3171 / Fax: 800-826-3487
 Overseas Fax: 260-563-0167
www.fordmeterbox.com

Submitted By: