



SUBMITTAL INFORMATION

Angle Ball Meter Valve Assembly - (BA43-444W-U-AWT-NL style)



ULTRA-TITE (CTS) COUPLING ASSEMBLED WATERTIGHT TO BALL VALVE WITH METER SWIVEL NUT



VALVE SIZE	ULTRA-TITE SERVICE LINE O.D.	METER SIZE	LENGTH	HEIGHT	APPROX. Wt. LBS	PART NUMBER	✓ SUBMITTED ITEM(S)
1"	1.12 - 1.13	1"	2-43/64"	4-15/64"	3.3	BA43-444W-U-AWT-NL	

FEATURES

- All brass components that come in contact with potable water conform to AWWA Standard C800 (UNS NO C89833)
- The product has the letters "NL" cast into the main body for proper identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B-62 and ASTM B-584, UNS NO C83600 - 85-5-5-5)
- Ends are integral or secured with adhesive to prevent unintentional disassembly
- Hole for attaching handle is provided in the tee head
- 300 PSI rated working pressure
- Padlock Wing for locking valve in closed position
- Ultra-Tite assembled watertight to ball valve
- Ball valve body design provides larger, more rugged wrench flats for easy installation
- **Optional** WW valves can be locked in either the open or closed position

Note: Recommended for inlet side shut-off.

Optional full 360° tee-head rotation. Add "R" to end of part number.

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



The Ford Meter Box Company, Inc.
 P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443
 Phone: 260-563-3171 / Fax: 800-826-3487
 Overseas Fax: 260-563-0167
<http://www.fordmeterbox.com>

Submitted By: