



# SUBMITTAL INFORMATION

## Pack Joint Coupling - (C27-xx-NL style)



### FLARE COPPER BY PACK JOINT FOR PVC PIPE



DESCRIPTION	FLARE COPPER	P.J. FOR PVC	LENGTH	APPROX. Wt. LBS	PART NUMBER	✓ SUBMITTED ITEM(S)
	3/4"	1/2"	2-1/2"	1.0	C27-31-NL	
	3/4"	3/4"	2-7/16"	1.4	C27-33-NL	
	3/4"	1"	2-9/16"	2.0	C27-34-NL	
	1"	1"	2-5/8"	2.1	C27-44-NL	

**Note:** Ford Pack Joints for PVC are only recommended for Schedule 40 and Schedule 80 pipe.

### FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters "NL" cast into the main body for lead-free identification
- Certified to NSF/ANSI Standard 61 and NSF/ANSI Standard 372 where applicable
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- Body design provides larger, more rugged wrench flats for proper installation

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



**The Ford Meter Box Company, Inc.**  
P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443  
Phone: 260-563-3171 / Fax: 800-826-3487  
Overseas Fax: 260-563-0167  
[www.fordmeterbox.com](http://www.fordmeterbox.com)

Submitted By: