



# SUBMITTAL INFORMATION

## Pack Joint Coupling - (C77-45-AWT-NL style)



**PACK JOINT FOR SCHEDULE 40 AND SCHEDULE 80 PVC OR DR-11 HDPE PIPE BOTH ENDS, ASSEMBLED WATERTIGHT**



| DESCRIPTION |            | LENGTH | APPROX.<br>WT. LBS | PART<br>NUMBER | ✓ SUBMITTED<br>ITEM(S) |
|-------------|------------|--------|--------------------|----------------|------------------------|
| PACK JOINT  | PACK JOINT |        |                    |                |                        |
| 1"          | 1-1/4"     | 3-3/4" | 2.5                | C77-45-AWT-NL  |                        |

**Note:** Ford Pack Joints for PVC are only recommended for Schedule 40 and Schedule 80 PVC pipe, or DR-11 HDPE pipe with appropriate insert stiffener.

### FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters "NL" cast into the main body for lead-free identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- Sleeve design provides larger, more rugged wrench flats for proper installation
- Ends are integral or secured with adhesive to prevent unintentional disassembly

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current. Our standard warranty applies.



#### The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443

Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167

www.fordmeterbox.com

10/27/20

Submitted By: