



SUBMITTAL INFORMATION

Pack Joint Coupling - (C87-67-AWT-NL style)



MALE IRON PIPE THREAD BY PACK JOINT FOR PVC PIPE COUPLING (ASSEMBLED WATERTIGHT)



| DESCRIPTION | | LENGTH | APPROX. WT. LBS | PART NUMBER | ✓ SUBMITTED ITEM(S) |
|----------------|--------------|---------|--------------------|----------------|------------------------|
| MALE IRON PIPE | P.J. FOR PVC | | | | |
| 1-1/2" | 2" | 5-5/32" | 5.3 | C87-67-AWT-NL | |

Note: Ford Pack Joints for PVC are only recommended for Schedule 40 and Schedule 80 pipe.

FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters "NL" cast into the main body for lead-free identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- Body design provides wrench lugs to assist in installation

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



The Ford Meter Box Company, Inc.
P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443
Phone: 260-563-3171 / Fax: 800-826-3487
Overseas Fax: 260-563-0167
www.fordmeterbox.com

Submitted By:

02/26/15