



# SUBMITTAL INFORMATION

## Ballcorp Corporation Stops - (FB1002-x-NL style)



### AWWA/CC TAPER THREAD INLET BY PACK JOINT FOR PVC PIPE OUTLET



Due to design variations related to sizing, items may differ from images above.

| VALVE SIZE | INLET SIZE | OUTLET SIZE | VALVE LENGTH | BODY OUTLET THREADS | APPROX. WT. LBS | PART NUMBER | ✓ SUBMITTED ITEM(S) |
|------------|------------|-------------|--------------|---------------------|-----------------|-------------|---------------------|
| 3/4"       | 3/4"       | 3/4"        | 4-7/16"      | 1" Flare Copper     | 1.9             | FB1002-3-NL |                     |
| 1"         | 1"         | 1"          | 4-5/16"      | 1-1/4" Flare Copper | 2.8             | FB1002-4-NL |                     |
| 1-1/4"     | 1-1/4"     | 1-1/4"      | 5-5/8"       | 1-1/2" Flare Copper | 5.1             | FB1002-5-NL |                     |
| 1-1/2"     | 1-1/2"     | 1-1/2"      | 5-27/32"     | 2" Flare Copper     | 5.8             | FB1002-6-NL |                     |
| 2"         | 2"         | 2"          | 7-5/8"       | 2" Flare Copper     | 10.4            | FB1002-7-NL |                     |

**Note:** Ford® Pack Joints for PVC are only recommended for Schedule 40 and Schedule 80 PVC pipe or DR11 HDPE pipe with appropriate insert stiffener.

### FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters "NL" cast into the main body for lead-free identification
- Certified to NSF/ANSI Standard 61 and NSF/ANSI Standard 372 where applicable
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- Ends are integral or secured with adhesive to prevent unintentional disassembly
- 300 PSI working pressure

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current. Our standard warranty applies.



**The Ford Meter Box Company, Inc.**  
P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443  
Phone: 260-563-3171 / Fax: 800-826-3487  
Overseas Fax: 260-563-0167  
www.fordmeterbox.com

07/13/21

Submitted By: