



SUBMITTAL INFORMATION

Steel Reducing Coupling - (FC6-xxxx-xxxx-E style)



16"-20" STYLE FC6 COUPLINGS (WITH EPOXY COATING) FOR JOINING PIPES WITH DIFFERENT O.D.'S



NOM PIPE SIZE	LARGE END				BY	NOM PIPE SIZE	SMALL END				APPROX. OVERALL LENGTH	CATALOG NUMBER	✓ SUBMITTED ITEM(S)			
	GASKET RANGE (IN.)	LENGTH L1	BOLT QTY.	DIM T1			GASKET RANGE (IN.)	LENGTH L2	BOLT QTY.	DIM T2						
16"-18"	17.40-17.80	5"	10	1/4" or 3/8"		14"-18"	15.30-15.70	7"	9	1/4" or 3/8"	13-1/2"	FC6-1780-1570-E				
	18.25		11				FC6-1780-1635-E									
							FC6-1780-1688-E									
	18.90-19.20	10	FC6-1825-1570-E													
			FC6-1825-1635-E													
			FC6-1825-1688-E													
	18"-20"	19.50-20.00	5"	11		1/4" or 3/8"		14"-18"	15.30-15.70	7"		9	1/4" or 3/8"	13-1/2"	FC6-2000-1570-E	
									17.40-17.80						10	FC6-2000-1780-E
18.25					11				FC6-2000-1825-E							
18.90-19.20					10				FC6-2000-1920-E							
21.60-22.06		5"	12	1/4" or 3/8"	18"-20"	19.50-20.00		7"	11	1/4" or 3/8"	13-1/2"	FC6-2206-1780-E				
												FC6-2206-1825-E				
												FC6-2206-1920-E				
												FC6-2206-2000-E				

Note: Flexible couplings do not restrain axial forces on piping.

FEATURES

- Sleeves - Carbon steel per ASTM A36
- Center Ring - Carbon steel per ASTM A36
- End Rings - Ductile iron per ASTM A536, grade 65-45-12, or carbon steel per AISI 1020/1018
- Bolts and Nuts - High strength, low alloy steel per ASTM A536 or AWWA C111
- Gasket - SBR rubber per ASTM D2000
- Finish - Fusion bonded epoxy - NSF 61 approved
- Complies with AWWA C219 standards

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current. Our standard warranty applies.



The Ford Meter Box Company, Inc.
P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443
Phone: 260-563-3171 / Fax: 800-826-3487
Overseas Fax: 260-563-0167
www.fordmeterbox.com

10/08/20

Submitted By: