


SUBMITTAL INFORMATION





18"-24" THREE SECTION ALL STAINLESS STEEL REPAIR CLAMPS



Bolts & Nuts
Type 304 stainless
steel bolts, nuts and
washers per ASTM
A193 and A194. Nuts
are coated to prevent
galling.

OUTLET THREAD TAP CODE CC (AWWA) Thread **IP Thread** Thread Code No. Code No. Thread 3/4" CC -CC3 3/4" IP -IP3 1" CC -CC4 1" IP -IP4 1-1/4" CC -CC5 1-1/4" IP -IP5 1-1/2" CC 1-1/2" IP -CC6 -IP6 2" IP 2" CC -CC7 -IP7

1		
	Optional Stainless Ta Type 304 stainless st welded to band. Avai AWWA or I.P. threads	– eel TIG lable with

Nom. PIPE	PIPE O.D.	LENGT	H AND A	PPROX.	WEIGHT	(LBS.)	Воцт	BAND	Cara an Number	✓ SUBMITTED
Size	RANGE (IN.)	12.5"	15"	20"	24"	30"	SIZE	THICKNESS	CATALOG NUMBER	İTEM
18"	18.21 - 19.41	35	44	56	68	84	5/8" 11 UNC	20 GA.	FS3-1941-Length	
	19.20 - 20.40								FS3-2040-Length	
20"	21.07 - 22.27 21.52 - 22.72	1 /11	48	60	73	89	5/8" 11 UNC	20 GA.	FS3-2227-Length FS3-2272-Length	
24"	23.18 - 24.38	46	53	65	79	102	5/8" 11 UNC	20 GA.	FS3-2438-Length	
	24.38 - 25.58								FS3-2558-Length	
	25.60 - 26.80								FS3-2680-Length	
	25.70 - 26.90								FS3-2690-Length	
Numbe	er of studs	12	12	18	21	27				

FEATURES

- NBR (Buna-N) gasket and conductivity strips are available
- Optional outlet taps are available for repair of service line pull-outs. Add tapping code to catalog number
- All welds are fully passivated to restore corrosion resistant characteristics of stainless steel
- · Certified to ANSI/NSF 61

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current. Our standard warranty applies.



The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443 Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167

www.fordmeterbox.com

08/26/22

•	*
Submitted By:	