



# SUBMITTAL INFORMATION

## 70 Series Tandem Coppersetter - (TVBHC74-xxW-77-44-NL style)



### ANGLE BALL VALVE BY ANGLE CARTRIDGE DUAL CHECK VALVE (1" METER)

### PACK JOINT FOR PVC PIPE INLET AND OUTLET



### Coppersetter Part Number

HEIGHT (INCHES)	APPROX. WT. LBS.	CATALOG NUMBER (INSERT SERVICE LINE CONN. SIZE)	✓ SUBMITTED ITEM(S)
15	13.5	TVBHC74-15W-77-44-NL	
18	15.0	TVBHC74-18W-77-44-NL	
21	15.3	TVBHC74-21W-77-44-NL	
24	15.7	TVBHC74-24W-77-44-NL	
27	16.0	TVBHC74-27W-77-44-NL	
30	16.3	TVBHC74-30W-77-44-NL	
33	16.6	TVBHC74-33W-77-44-NL	
36	16.9	TVBHC74-36W-77-44-NL	
39	17.2	TVBHC74-39W-77-44-NL	
42	17.5	TVBHC74-42W-77-44-NL	


### Adapters for Regulator (MIP by Male Meter Thread)

CATALOG NUMBER	METER SIZE	ADAPTER LENGTH	APPROX. WT. LBS.
RA-4-NL	1"	2-1/4"	1.3

### Service Line Size

INLET	OUTLET
1" (PVC) PJ Nut	1" (PVC) PJ Nut

**Note:** Ford pack joints for PVC are recommended only for schedule 40 and schedule 80 pipe.



### FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters "NL" cast into the main body for lead-free identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- Certified to NSF/ANSI/CAN Standard 61 and NSF/ANSI/CAN Standard 372 where applicable
- Copper conforms to ASTM B75 or B88, UNS C12200
- All Ford® Setters are assembled with lead-free solder
- Bracing eye is standard on all 70 Series Coppersetters
- Tie bar is standard for 24" and taller Coppersetter heights (TVBHC74 Series)
- 1-1/8" O.D. copper risers provide more flow capacity
- Unless specified otherwise, Tandem Coppersetters are designed to hold a water meter in series with a pressure regulator
- Tandem Coppersetters include an "S" tube and a pair of male iron pipe by male meter thread regulator adapters for holding a pressure regulator
- ASSE 1024 approved dual cartridge check valve

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current. Our standard warranty applies.



### The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443

Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167

[www.fordmeterbox.com](http://www.fordmeterbox.com)

2/27/25

Submitted By: