
# SUBMITTAL INFORMATION





APPROX.


WT. LBS.

1.3

2-1/4"

### ANGLE BALL VALVE BY ANGLE CARTRIDGE DUAL CHECK VALVE (1" METER)

## FLARE COPPER INLET AND OUTLET




# Coppersetter Part Number

Неіднт	APPROX. Wt. Lbs.	CATALOG NUMBER	✓ SUBMITTED ITEM(S)
15"	7.1	TVBHC84W-22-44-NL	

# Adapters for Regulator (MIP by Male Meter Thread)







## **Service Line Size**

INLET	OUTLET	SERVICE LINE CONN. SIZE	✓ SUBMITTED  ITEM(S)
1" Flare Copper	1" Flare Copper	44	

#### **FEATURES**

- All brass components that come in contact with potable water conform to AWWA Standard C800 (UNS NO C89833)
- The product has the letters "NL" cast into the main body for proper identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B-62 and ASTM B-584, UNS NO C83600 - 85-5-5-5)
- Full Port Dual Cartridge Check Valve is ASSE 1024 approved
- Saddle nuts hold the meter in place for tightening
- 1-1/8" Copper Risers provide more flow capacity
- All Ford Setters are assembled with lead-free solder
- Unless specified otherwise, Tandem Coppersetters are designed to hold a water meter in series with a pressure regulator
- Tandem Coppersetters include an "S" tube and a pair of male iron pipe by male meter thread regulator adapters for holding a pressure regulator
- Copper conforms to ASTM B-88, Copper Alloy #122

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



Meter Nut

## The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443 Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167 http://www.fordmeterbox.com

01/28/14

_	•		
Sı	ıhr	nitted	1 Rv