

## SUBMITTAL INFORMATION





## FEMALE IRON PIPE THREAD INLET BY TWO MALE IRON PIPE THREAD OUTLETS



DESCRIPTION			Unioun	Approx.	Part	✓ SUBMITTED	
FIP INLET	2-MIP OUTLETS	LENGTH	HEIGHT	Wt. Lbs	Number	ITEM(S)	
1"	3/4"	1-5/8"	1-3/8"	2.1	UA11-43-65-NL		

## **FEATURES**

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters "NL" cast into the main body for lead-free identification
- Certified to NSF/ANSI Standard 61 and NSF/ANSI Standard 372 where applicable
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- All angle "U" branches have 6-1/2" spacing

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



## The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443 Phone: 219-563-3171 / Fax: 800-826-3487

Overseas Fax: 219-563-0167

www.fordmeterbox.com

10/12/16

_	-		_
c.	ıhn	nitted	D.
OI	ш	mueo	DV

ubmitted By:			