


SUBMITTAL INFORMATION

Uni-Flange® Restraint - (UFR1399-C-x-RB-I style)



UNI-FLANGE SERIES 1399-C RESTRAINT HARNESS (WITH BLUE FLUOROCARBON COATED HARDWARE)
FOR C900 PVC, C909 PVC AND C906 HDPE BELL JOINTS





Nom Pipe Size	PVC PIPE WITH DI PIPE OD STYLE 1399-C		A	B Approx.	C Max	RESTRAINING BOLTS / RODS		CLAMPING BOLTS		MAX BELL	Approx	(
										CLEARANCE	APPROX. Wt. Lbs.	✓ SUBMITTED ITEM(S)
	OD	CATALOG NO.		AT TROX.	MAX	No.	Size	No.	SIZE	OLLANANOL		TTEM(0)
	(IN.)											
4"	4.80	UFR1399-C-4-RB-I	2-13/64"	10-13/16"	15"	2	3/4" x 17"	4	5/8" x 2-1/2"	6.63"	17.69	
6"	6.90	UFR1399-C-6-RB-I	2-13/64"	12-13/16"	15"	2	3/4" x 17"	4	5/8" x 2-1/2"	8.63"	20.48	
8"	9.05	UFR1399-C-8-RB-I	2-13/64"	16-47/64"	15"	2	3/4" x 17"	4	5/8" x 3"	14.00"	33.39	
10"	11.10	UFR1399-C-10-RB-I	2-1/4"	19-1/16"	22"	4	3/4" x 24"	4	5/8" x 3"	14.13"	61.14	
12"	13.20	UFR1399-C-12-RB-I	2-13/64"	21-3/8"	22"	4	3/4" x 24"	4	5/8" x 3"	16.63"	72.46	

FEATURES

- Cast ductile iron per ASTM A536 grade 65-45-12
- Restraining rods (included) High strength, low alloy steel ANSI / AWWA C111 / A21.11, blue fluorocarbon coated
- Side clamping bolts and nuts Grade 5, zinc-plated, blue fluorocarbon coated
- Clamping pads and tie rod lugs are co-located so installer doesn't have to work under the pipe
- Rated at full-rated pressure of any class of C900 and C909 PVC pipe, minimum 2:1 safety factor
- Rated at full-rated pressure of any class of C906 HDPE pipe (provided an insert is used)
- Black Armorguard e-coat applied epoxy
- 360° contact and support of the pipe wall

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current. Our standard warranty applies.



The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443 Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167

www.fordmeterbox.com

Submitted By:

08/16/24