

SUBMITTAL INFORMATION



Uni-Flange® Mechanical Joint Restraint - (UFR1500-CA-xx-EPDM-I style)




42" & 48" SERIES UFR1500-C MECHANICAL JOINT RESTRAINT FOR C900 WITH EPDM GASKET

Ductile iron wedge actuating screw, with the Auto-Tork break-away head design, ensures proper torque during installation.

Gland body is of high strength ductile iron per ASTM A536, Grade 65-45-12. Compatible with all mechanical joints conforming to ANSI/AWWA C111/A21.11.



Ring segments are ductile iron per ASTM A536 and heat treated to a hardness of 310 BHN minimum



EPDM Uni-Seal gasket included

Front

Back

NOM. PIPE SIZE (IN.)	PIPE O.D. (IN.)	CATALOG NUMBER	NO. OF WEDGES	APPROX. WEIGHT (LBS.)	P (IN.)	C (IN.)	D (IN.)	F (IN.)	J (IN.)	PRESSURE RATING C900 DR25	✓ SUBMITTED ITEM(S)
42	44.50	UFR1500-CA-42-EPDM-I	28	476	53.9	45.79	5.68	44.79	50.62	165 PSI	
48	50.80	UFR1500-CA-48-EPDM-I	32	573	60.2	52.09	5.67	51.09	57.50	165 PSI	

FEATURES

- The Series 1500 can be used on AWWA C900 PVC
- Auto-Tork actuating screws with heads specially designed to twist off at the correct installation torque, leaving a hex head for future system maintenance or removal
- High strength, low alloy t-bolts and nuts per AWWA C111
- EPDM Uni-Seal gasket per ASTM D2000
- Series 1500 eliminates the need to pour expensive and time consuming concrete thrust blocks
- Restraining segments are mechanically retained in pockets
- Gland, screws and segments are black epoxy coated using the e-coat process
- Gland colored red for identification purposes

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current. Our standard warranty applies.



The Ford Meter Box Company, Inc.
P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443
Phone: 260-563-3171 / Fax: 800-826-3487
Overseas Fax: 260-563-0167
www.fordmeterbox.com

06/29/21

Submitted By: