


SUBMITTAL INFORMATION






ANGLE BALL VALVE BY METER NUT (5/8" METER)

PACK JOINT FOR COPPER OR PLASTIC TUBING (CTS) INLET BY DOUBLE PURPOSE UNION SWIVEL OUTLET



Coppersetter Part Number							
HEIGHT	APPROX.	CATALOG NUMBER	✓ SUBMITTED				
(INCHES)	Wt. LBs.	(INSERT SERVICE LINE CONN. SIZE)	ITEM(S)				
7	4.2	VB71-7W-41-xx-NL					
9	4.4	VB71-9W-41-xx-NL					
12	4.6	VB71-12W-41-xx-NL					
15	4.8	VB71-15W-41-xx-NL					
18	5.5	VB71-18W-41-xx-NL					
21	5.7	VB71-21W-41-xx-NL					
24	6.0	VB71-24W-41-xx-NL					
27	6.2	VB71-27W-41-xx-NL					
30	6.5	VB71-30W-41-xx-NL					
33	6.8	VB71-33W-41-xx-NL					
36	7.0	VB71-36W-41-xx-NL					
39	7.3	VB71-39W-41-xx-NL					
42	7.6	VB71-42W-41-xx-NL					



Service Line Size

INLET	OUTLET	SERVICE LINE CONN. SIZE	✓ SUBMITTED ITEM(S)
3/4" (CTS) P.J.	3/4" D.P. Swivel	33	
1" (CTS) P.J.	3/4" D.P. Swivel	43	
1" (CTS) P.J.	1" D.P. Swivel	44	

Note: Ford recommends using insert stiffeners with plastic pipe or tubing

FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters "NL" cast into the main body for lead-free identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- Certified to NSF/ANSI/CAN Standard 61 and NSF/ANSI/CAN Standard 372 where applicable
- Copper conforms to ASTM B75 or B88, UNS C12200
- All Ford® Setters are assembled with lead-free solder
- Saddle nuts hold the meter in place for tightening
- Bracing eye is standard on all 70 Series Coppersetters
- Tie bar is standard for 18" and taller Coppersetter heights (71 Series)
- Double purpose union swivels will accommodate male iron pipe threads or flare copper
- 13/16" copper risers provide more flow capacity

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current. Our standard warranty applies.



The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443 Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167 www.fordmeterbox.com

04/18/24

	nitte	