



SUBMITTAL INFORMATION

70 Series Coppersetter - (VB74-xxW-44-46-FP-Q-NL style)



FULL PORT ANGLE BALL VALVE BY METER NUT (1" METER)

QUICK JOINT FOR COPPER OR PLASTIC TUBING (CTS) INLET AND OUTLET



Coppersetter Part Number

| HEIGHT (INCHES) | APPROX. WT. LBS. | CATALOG NUMBER | ✓ SUBMITTED ITEM(S) |
|--------------------|---------------------|------------------------|------------------------|
| 10 | 7.5 | VB74-10W-44-46-FP-Q-NL | |
| 12 | 7.6 | VB74-12W-44-46-FP-Q-NL | |
| 15 | 7.9 | VB74-15W-44-46-FP-Q-NL | |
| 18 | 8.2 | VB74-18W-44-46-FP-Q-NL | |
| 21 | 9.7 | VB74-21W-44-46-FP-Q-NL | |
| 24 | 10.1 | VB74-24W-44-46-FP-Q-NL | |
| 27 | 10.4 | VB74-27W-44-46-FP-Q-NL | |
| 30 | 10.7 | VB74-30W-44-46-FP-Q-NL | |
| 33 | 11.0 | VB74-33W-44-46-FP-Q-NL | |
| 36 | 11.3 | VB74-36W-44-46-FP-Q-NL | |
| 39 | 11.6 | VB74-39W-44-46-FP-Q-NL | |
| 42 | 11.9 | VB74-42W-44-46-FP-Q-NL | |

Service Line Size

| INLET | OUTLET |
|---------------|-------------------|
| 1" (CTS) Q.J. | 1-1/2" (CTS) Q.J. |

Note: Ford recommends using insert stiffeners with plastic pipe or tubing

FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters "NL" cast into the main body for lead-free identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- Certified to NSF/ANSI/CAN Standard 61 and NSF/ANSI/CAN Standard 372 where applicable
- Copper conforms to ASTM B75 or B88, UNS C12200
- All Ford® Setters are assembled with lead-free solder
- Bracing eye is standard on all 70 Series Coppersetters
- Tie bar is standard for 21" and taller Coppersetter heights (74 Series)
- 1-1/8" copper risers provide more flow capacity
- Full inlet ball valve port

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current. Our standard warranty applies.



The Ford Meter Box Company, Inc.
P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443
Phone: 260-563-3171 / Fax: 800-826-3487
Overseas Fax: 260-563-0167
www.fordmeterbox.com

01/02/24

Submitted By: