



SUBMITTAL INFORMATION

270 Series Coppersetter - (VBB272-xxW-NL style)



ANGLE BALL VALVE BY *ANGLE BALL VALVE (5/8" X 3/4" METER)


MALE THREADS FOR PACK JOINT ASSEMBLIES INLET AND OUTLET



Coppersetter Part Number


HEIGHT (INCHES)	APPROX. WT. LBS.	CATALOG NUMBER	✓ SUBMITTED ITEM(S)
7	5.0	VBB272-7W-NL	
9	5.2	VBB272-9W-NL	
12	5.4	VBB272-12W-NL	
15	5.6	VBB272-15W-NL	
18	6.3	VBB272-18W-NL	
21	7.0	VBB272-21W-NL	
24	7.7	VBB272-24W-NL	
27	8.4	VBB272-27W-NL	
30	9.1	VBB272-30W-NL	
33	9.8	VBB272-33W-NL	
36	10.5	VBB272-36W-NL	
39	11.2	VBB272-39W-NL	
42	11.9	VBB272-42W-NL	

*The Angle Ball Valve is a one-way directional valve designed for the inlet side of the meter and should not be used as a customer shut-off on the customer side of the meter.



Service Line Connection

Please see the Pack Joint Assembly Submittal in Section F (PJAx-1x-NL)



FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters "NL" cast into the main body for lead-free identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- Copper conforms to ASTM B75, UNS C12200
- Saddle nuts hold the meter in place for tightening
- Two pack joint assemblies required (PJAx-1x-NL) inlet and outlet - order separately
- Tie bar is standard for 18" and taller Coppersetter heights (272 Series)
- 13/16" copper risers provide more flow capacity
- All Ford Setters are assembled with lead-free solder

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



The Ford Meter Box Company, Inc.
P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443
Phone: 260-563-3171 / Fax: 800-826-3487
Overseas Fax: 260-563-0167
www.fordmeterbox.com

06/23/17

Submitted By: