



SUBMITTAL INFORMATION

40 Series Resetter - (VBHC142-xxW-FP-NL style)



FULL PORT ANGLE BALL VALVE BY ANGLE CARTRIDGE DUAL CHECK VALVE (5/8" X 3/4" METER)

METER THREAD INLET AND OUTLET



Resetter Part Number

| HEIGHT (INCHES) | APPROX. WT. LBS. | CATALOG NUMBER | ✓ SUBMITTED ITEM(S) |
|-----------------|------------------|-------------------|---------------------|
| 9 | 5.6 | VBHC142-9W-FP-NL | |
| 12 | 5.8 | VBHC142-12W-FP-NL | |
| 15 | 6.0 | VBHC142-15W-FP-NL | |
| 18 | 6.7 | VBHC142-18W-FP-NL | |
| 21 | 6.9 | VBHC142-21W-FP-NL | |
| 24 | 7.2 | VBHC142-24W-FP-NL | |
| 27 | 7.4 | VBHC142-27W-FP-NL | |
| 30 | 7.7 | VBHC142-30W-FP-NL | |

Meter Thread Size

| INLET | OUTLET |
|-------|--------|
| 3/4" | 3/4" |

FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (ASTM B584, UNS C89833)
- The product has the letters "NL" cast into the main body for lead-free identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B62 and ASTM B584, UNS C83600, 85-5-5-5)
- Certified to NSF/ANSI/CAN Standard 61 and NSF/ANSI/CAN Standard 372 where applicable
- Copper conforms to ASTM B75 or B88, UNS C12200
- All Ford® Setters are assembled with lead-free solder
- Saddle nuts hold the meter in place for tightening
- Tie bar is standard for 21" and taller resetter heights (40 Series)
- Conforms to AWWA C700 for meter threads
- 13/16" copper risers provide more flow capacity
- ASSE 1024 approved cartridge dual check valve
- Full port ball valve on inlet

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current. Our standard warranty applies.



The Ford Meter Box Company, Inc.
P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443
Phone: 260-563-3171 / Fax: 800-826-3487
Overseas Fax: 260-563-0167
www.fordmeterbox.com

08/22/23

Submitted By: