

SUBMITTAL INFORMATION






ANGLE KEY VALVE BY ANGLE CHECK VALVE (5/8" X 3/4" METER)

PACK JOINT FOR COPPER OR PLASTIC TUBING (CTS) INLET BY MALE IRON PIPE SWIVEL OUTLET



Coppersetter Part Number

HEIGHT	APPROX.	CATALOG NUMBER	√ SUBMITTED
(INCHES)	Wt. LBS.	(Insert Service Line Conn. Size)	ITEM(S)
7	5.5	VH72-7W-48-xx-NL	
9	5.7	VH72-9W-48-xx-NL	
12	5.9	VH72-12W-48-xx-NL	
15	6.1	VH72-15W-48-xx-NL	
18	6.8	VH72-18W-48-xx-NL	
21	7.0	VH72-21W-48-xx-NL	
24	7.3	VH72-24W-48-xx-NL	
27	7.5	VH72-27W-48-xx-NL	
30	7.8	VH72-30W-48-xx-NL	
33	8.1	VH72-33W-48-xx-NL	
36	8.3	VH72-36W-48-xx-NL	
39	8.6	VH72-39W-48-xx-NL	
42	8.9	VH72-42W-48-xx-NL	



Service Line Size

INLET	OUTLET	SERVICE LINE CONN. SIZE	√ SUBMITTED ITEM(S)
3/4" (CTS) P.J.	3/4" MIP Swivel	33	
1" (CTS) P.J.	3/4" MIP Swivel	43	
1" (CTS) P.J.	1" MIP Swivel	44	

Note: Ford recommends using insert stiffeners with plastic pipe or tubing

FEATURES

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (UNS NO C89833)
- The product has the letters "NL" cast into the main body for proper identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B-62 and ASTM B-584, UNS NO C83600 - 85-5-5-5)
- Saddle Nuts hold the meter in place for tightening
- Bracing Eye is standard on all 70 Series Coppersetters
- Tie Bar is standard for 18" and taller Coppersetter heights (72 Series)
- 13/16" Copper Risers provide more flow capacity
- Copper conforms to ASTM B-75, Copper Alloy #122
- · All Ford Setters are assembled with lead-free solder

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443 Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167

http://www.fordmeterbox.com

Submitted By:

12/20/13		