

# SUBMITTAL INFORMATION





#### STRAIGHT BALL VALVE BY STRAIGHT DUAL CARTRIDGE CHECK VALVE

## PACK JOINT FOR PVC INLET AND OUTLET



Note: Ford Pack Joints for PVC are only recommended for Schedule 40 and Schedule 80 pipe.

### **FEATURES**

- All brass that comes in contact with potable water conforms to AWWA Standard C800 (UNS NO C89833)
- The product has the letters "NL" cast into the main body for proper identification
- Brass components that do not come in contact with potable water conform to AWWA Standard C800 (ASTM B-62 and ASTM B-584, UNS NO C83600 - 85-5-5-5)
- Base and upper section are cast iron per ASTM A48, Class 25
- Plastic locking lid
- The dual cartridge check valve is ASSE 1024 approved
- The brass end fittings are permanently and properly spaced and aligned for the meter
- Finish is black E-coating

The Ford Meter Box Company considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice. Please verify that your product information is current.



## The Ford Meter Box Company, Inc.

P.O. Box 443, Wabash, Indiana U.S.A. 46992-0443

Phone: 260-563-3171 / Fax: 800-826-3487

Overseas Fax: 260-563-0167 http://www.fordmeterbox.com

02/14/13

$\overline{}$	_	****	)
ธน	nn	nitted	BV